



Certificate of Conformity

Certificate number: CM40114 Rev2

THIS TO CERTIFY THAT

RMAX ThermaWallPlus™ Direct Fix or Batten Cavity Fix (EIFS) Cladding Systems

Certification Body:



ABN: 80 111 217 568
JAS-ANZ Accreditation
No. Z4450210AK
PO Box 7144, Sippy
Downs Qld 4556
+61 (07) 5445 2199
www.CertMark.org

Certificate Holder:



ABN: 48 004 146 338
2 - 4 Mephan Street
Maribyrnong
VIC 3032
Ph: 61 3 9318 4422
W: www.rmax.com.au
VIC:
vicsales@rmax.com.au
WA:
wasales@rmax.com.au
NSW:
nswsales@rmax.com.au

Type and/or use of product:

The RMAX ThermaWallPlus™ Direct Fix or Batten Cavity Fix (EIFS) Cladding Systems are certified for use as an external insulation finishing system (EIFS) in class 1 and 10 buildings. Either system can be applied to steel or timber frames.

Description of product:

The RMAX ThermaWallPlus™ External Insulated Finishing System (EIFS) Panels are made from Isolite® closed cell Expanded Polystyrene (EPS) bead material (density grade M).

COMPLIES WITH THE FOLLOWING BCA PROVISIONS AND STATE OR TERRITORY VARIATION(S)

BCA 2016

	Volume One	Volume Two
Performance Requirement(s)	Not applicable to this Product	P2.1.1(a)&(b)(i),(ii),(iii) Structural for External Wall Cladding ^(b) P2.2.2 Weatherproofing for External Wall Cladding ^(c) P2.3.4 Bushfire Areas for External Wall Cladding ^(d) P2.6.1 Energy Efficiency for External Walls
Deemed-to-Satisfy Provision(s):	Not applicable to this Product	Not applicable to this Product TAS P2.3.4 VIC P2.6.1 In New South Wales, Part 2.6 does not apply. In the Northern Territory, Part 2.6 is replaced with BCA 2009 Part 2.6.
State or territory variation(s):	Not applicable to this Product	

SUBJECT TO THE FOLLOWING LIMITATIONS AND CONDITIONS AND THE PRODUCT TECHNICAL DATA IN APPENDIX A AND EVALUATION STATEMENTS IN APPENDIX B

Limitations and conditions:

- Wind load resistance is dependent on panel thickness, stud spacing and fastener spacing. Please see RMAX Technical Data and Installation Manuals, [08 -17 Batten Cavity Fix Version 4_0 Codemark](#) and [08 - 17 Direct Fix version 4_0 Codemark](#), for performance ratings.
- Minimum BMT of steel frames must be 1.0mm.
- The RMAX ThermaWallPlus™ Direct Fix or Batten Cavity Fix (EIFS) Cladding System must be installed with breathable sarking installed behind the EPS.
- Is only suitable for applications up to a maximum of BAL-29 when constructed using 75mm and 100mm thick board on both direct fix or batten cavity fix applications, with minimum 4.8mm thick RMAX Orange Board™ Plus Render System on external face of external walls, 90mm x 45mm timber frame and 10mm thick plasterboard on internal face. Only valid when rendered side, faces fire front.

Building classification/s:

Class 1 and 10

John Thorpe - CMI

Don Grehan – Unrestricted Building Certifier

Date of issue: 11/08/2017

Date of expiry: 17/07/2020





Certificate of Conformity

Scope of certification: The CodeMark Scheme is a building product certification scheme. The rules of the Scheme are available at the ABCB website www.abcb.gov.au. This Certificate of Conformity is to confirm that the relevant requirements of the Building Code of Australia (BCA) as claimed against have been met. The responsibility for the product performance and its fitness for the intended use remain with the certificate holder. The certification is not transferrable to a manufacturer not listed on Appendix A of this certificate.

Disclaimer: The Scheme Owner, Scheme Administrator and Scheme Accreditation Body do not make any representations, warranties or guarantees, and accept no legal liability whatsoever arising from or connected to, the accuracy, reliability, currency or completeness of any material contained within this certificate; and the Scheme Owner, Scheme Administrator and Scheme Accreditation Body disclaim to the extent permitted by law, all liability (including negligence) for claims of losses, expenses, damages and costs arising as a result of the use of the product(s) referred to in this certificate.



Certificate of Conformity

APPENDIX A – PRODUCT TECHNICAL DATA

A1 Type and intended use of product

As per page one.

A2 Description of product

The ThermaWallPlus™ Panels are reinforced with high strength alkaline fibreglass mesh and the RMAX Orange Board™ Plus Render surface coating. The panels are fixed to the structural frame either vertically or horizontally using either 10G class 3 or 4 screws and 40mm diameter washers. Panels can be attached directly to the stud frame or through RMAX X28 EPS battens to create a cavity. The panel thicknesses covered by this certification are 60mm, 75mm and 100mm.

A3 Product specification

Overall thermal performance of a wall system will vary with panel thickness. Refer RMAX Technical Data and Installation Manuals, 08 -17 Batten Cavity Fix Version 4_0 Codemark and 08 - 17 Direct Fix version 4_0 Codemark for suitable constructions and climate zone information.

Total R Value of RMAX ThermaWallPlus™ Direct Fix (EIFS) EPS Cladding Wall System		
Standard Cladding Panel Thickness (mm)	Total R Value Summer (m ² K/W)	Total R Value Winter (m ² K/W)
60	1.93	2.04
75	2.32	2.44
100	2.96	3.12

Total R Value of RMAX ThermaWallPlus™ Batten Cavity Fix (EIFS) EPS Cladding Wall System		
Standard Cladding Panel Thickness (mm)	Total R Value Summer (m ² K/W)	Total R Value Winter (m ² K/W)
60	2.09	2.21
75	2.48	2.61
100	3.13	3.29

Total R Value of RMAX ThermaWallPlus™ Direct Fix (EIFS) EPS Cladding Wall System, Including Reflective Sarking		
Standard Cladding Panel Thickness (mm)	Total R Value Summer (m ² K/W)	Total R Value Winter (m ² K/W)
60	2.41	2.51
75	2.79	2.92
100	3.43	3.59

Total R Value of RMAX ThermaWallPlus™ Batten Cavity Fix (EIFS) EPS Cladding Wall System, Including Reflective Sarking		
Standard Cladding Panel Thickness (mm)	Total R Value Summer (m ² K/W)	Total R Value Winter (m ² K/W)
60	2.57	2.68
75	2.95	3.09
100	3.59	3.75

Panel Thickness	Surface Mass (Unrendered)	Sheet weight (Unrendered)
60mm	1.14kg/m ²	3.4kg
75mm	1.43kg/m ²	4.3kg
100mm	1.90kg/m ²	5.7kg



Certificate of Conformity

A4 Manufacturer and manufacturing plant(s)

RMAX (VIC) 2 - 4 Mephan Street, Maribyrnong VIC 3032.	RMAX (WA) 5 Baldwin Street, Kewdale WA 6105	RMAX (NSW) 27 Chifley Street, Smithfield NSW 2164
---	---	---

A5 Installation requirements

1. The RMAX ThermaWallPlus™ Direct Fix or Batten Cavity Fix (EIFS) Cladding System™ must be installed in accordance with the respective RMAX Technical Data and Installation Manuals, [08 -17 Batten Cavity Fix Version 4 0 Codemark](#) and [08 - 17 Direct Fix version 4 0 Codemark](#).
2. In cyclonic wind regions, panel joints must incorporate a double stud. Shared studs may only be used if project specific engineering approval is provided.
3. Fixing screws must be 25mm longer than the panel thickness for timber frame construction and 15mm longer than the panel thickness for steel frames.
4. Fasteners must be offset 20mm from stud edge.

A6 Other relevant technical data

Wind Regions	Non-Cyclonic (A & B)						Cyclonic (C & D)			
Wind category	N1	N2	N3	N4	N5	N6	C1	C2	C3	C4
Panel Thickness (mm)	60mm, 75mm, 100mm						75mm, 100mm			
Stud Spacing (mm)	300mm, 450mm, 600mm				300mm, 450mm		300mm			
Fastener Spacing (mm)	300mm (150mm at perimeter of wall)	300mm (150mm at perimeter of wall)	300mm (150mm at perimeter of wall)	300mm (150mm at perimeter of wall)	300mm (150mm at perimeter of wall)	200mm (150mm at perimeter of wall)	200mm (150mm at perimeter of wall)	200mm (150mm at perimeter of wall)	200mm (150mm at perimeter of wall)	200mm (150mm at perimeter of wall)
Number of Fasteners/m ²	12	12	12	12	12	18	18	18	18	18

RMAX ThermaWallPlus™ Direct Fix Cladding Product Range Weighted Sound Reduction Index (Rw) Performance

Panel Thickness	Construction	Rw
75mm	75mm Panel only + Frame + Sarking	12dB
75mm	75mm Panel + 8mm thick Render + Sarking + Frame + 10mm thick Plaster (Full wall system)	44dB

RMAX ThermaWallPlus™ Batten Cavity Fix Cladding Product Range Weighted Sound Reduction Index (Rw) Performance

Panel Thickness	Construction	Rw
75mm	75mm Panel only + 25mm Batten + Frame + Sarking	12dB
75mm	75mm Panel + 25mm Batten + 8mm thick render + Sarking + Frame + 10mm thick Plaster (Full wall system)	44dB



Certificate of Conformity

AS 1530.3:1999 Fire Indices

Fire resistance as tested on rendered ThermaWallPlus™ Panel	
Ignitability Index	0
Spread of Flame Index	0
Heat Evolved Index	0
Smoke Developed Index	4

APPENDIX B – EVALUATION STATEMENTS

B1 Evaluation methods

1. Structural Provision 1.2.2 (a)(i) & (iii). Reports from NATA accredited test laboratories and certificates from Professional Engineer.
2. Weatherproofing 1.2.2 (a)(i) & (iii). Reports from NATA accredited test laboratories and certificates from Professional Engineer.
3. Thermal Provision 1.2.2 (a)(i) & (iii). Reports from NATA accredited test laboratories and certificates from Professional Engineer.
4. Bushfire Prone Areas 1.2.2 (a)(i) & (iii). Reports from NATA accredited test laboratories and certificates from Professional Engineer.

B2 Reports

1. Vipac Engineers & Scientists; NATA #676; Report No. 30B-11-0103-TRP—601219-1, 450mm Shared Stud Test Report Wind load resistance dated 03/08/2011. Compliance to Structural provision of the BCA.
2. Vipac Engineers & Scientists; NATA #676; Report No. 30B-10-0337-TRP-598046-0, RMAX ThermaWallPlus™ Performance against AS 4284:2008 dated 27/05/2011. Compliance with Weatherproofing provision.
3. Vipac Engineers & Scientists; NATA #676; Report No. 30B-11-0103-TRP-598234-2, RMAX ThermaWallPlus™ Cyclonic Region Performance dated 09/08/2011. Compliance to P2.1.1
4. Skip Consulting Pty Ltd; Appraisal Project No. SKC10-154-BRAC-ThermaWallPlus™, Engineering report confirming compliance with P2.1.1 & P2.2.2 for ThermaWallPlus™ dated 11/06/2010.
5. AWTA; NATA #1356; 7-582752-NV RMAX ThermaSilver™ EPS Test Report 19/12/2011, in accordance with AS 1366.3:1992. Compliance to Energy Efficiency for external walls.
6. Ian Benney; NATA #2371; Report No. 2015-108-S1; Weatherproofing Test In accordance with AS/NZS 4284:2008 Testing of building facades, dated 11/02/2016.
7. Petrovic Engineering; Report No. 16-37; Weatherproofing and Wind Load Resistance Batten Cavity & Direct Fix dated 27/02/2017.
8. Petrovic Engineering; Report No. 17-05; Impact Load Resistance Batten Cavity & Direct Fix - AS/NZS 1170.2:2011 dated 27/02/2017. Compliance to Structural provision of the BCA.
9. Petrovic Engineering; Report No. 17-13; Wind Pressures above 10m Height - AS/NZS 1170.2:2011 dated 20/03/2017. Compliance to Structural provision of the BCA.
10. Exova Warringtonfire; NATA #3277; Assessment Report No. 47899700.2, Testing Report against AS 1530.8.1- 2007 dated 30/04/2017. Compliance to Bushfire Prone Areas provision.